Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2585/2021-22					Date	06.12.2021
TEST RESULTS ON CONCRETE CUBES							
Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.						
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.						
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport Road GKVK Post, Bengaluru.						
Name of Agency	Mr.H.V.Omkarappa Bengaluru.						
Clients Letter Dated	05.12.2021						
Date of Sample Received	05.12.2021						
Source of Sample	Supplied by the Client						
Dimensions of Specimens in mm	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
Grade of Concrete	M25						

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by the client and the results are tabulated here below

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Second Floor Column Concrete (Health Building in B-Sector)	28.11.2021	05.12.2021	7 Days	22500.00	8140	441.2	19.61
2		28.11.2021	05.12.2021		22500.00	8195	458.0	20.36
3		28.11.2021	05.12.2021		22500.00	8170	446.7	19.85

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

Approved by
Narayanswamy.B

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2586/2021-22	Date	27.12.2021

TEST RESULTS ON CONCRETE CUBES

Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport Road GKVK Post, Bengaluru.
Name of Agency	Mr.H.V.Omkarappa Bengaluru.
Clients Letter Dated	26.12.2021
Date of Sample Received	26.12.2021
Source of Sample	Supplied by the Client
Dimensions of Specimens in mm	150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0
Grade of Concrete	M25

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Second Floor Column Concrete (Health Building in B-Sector)	28.11.2021	26.12.2021	28 Days	22500.00	8260	662.4	29.44
2		28.11.2021	26.12.2021		22500.00	8215	667.1	29.65
3		28.11.2021	26.12.2021		22500.00	8250	670.5	29.80

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2596/2021-22				Date	27.12.2021
TEST RESULTS ON CONCRETE CUBES						
Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.					
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.					
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.					
Name of Agency	Mr.H.V.Omkarappa Bengaluru.					
Clients Letter Dated	26.12.2021					
Date of Sample Received	26.12.2021					
Source of Sample	Supplied by the Client					
Dimensions of Specimens in mm	150.0	x	150.0	x	150.0	
	150.0	x	150.0	x	150.0	
	150.0	x	150.0	x	150.0	
Grade of Concrete	M25					

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by the client and the results are tabulated here below

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Second Floor Roff Slab & Beam Concrete (Health Building in B Sector)	19.12.2021	26.12.2021	7 Days	22500.00	8160	498.0	22.13
2		19.12.2021	26.12.2021		22500.00	8145	489.3	21.75
3		19.12.2021	26.12.2021		22500.00	8230	485.4	21.57

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

AE

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

.....End of Report.....

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2597/2021-22					Date	17.01.2022
TEST RESULTS ON CONCRETE CUBES							
Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.						
Name of Project & Address	Construction of Class Rooms & Providing Basic Amenities to Yelahanaka Govt First Grade Collage in Yelahanaka Division, Bengaluru.						
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.						
Name of Agency	Mr.H.V.Omkarappa Bengaluru.						
Clients Letter Dated	16.01.2022						
Date of Sample Received	16.01.2022						
Source of Sample	Supplied by the Client						
Dimensions of Specimens in mm	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
Grade of Concrete	M25						

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Second Floor Roff Slab & Beam Concrete (Health Building in B Sector)	19.12.2021	16.01.2021	28 Days	22500.00	8210	648.1	28.80
2		19.12.2021	16.01.2021		22500.00	8195	655.4	29.13
3		19.12.2021	16.01.2021		22500.00	8175	679.1	30.18

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2581/2021-22	Date	11.01.2022

TEST RESULTS ON CONCRETE CUBES

Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.
Name of Agency	Mr.H.V.Omkarappa Bengaluru.
Clients Letter Dated	10.01.2022
Date of Sample Received	10.01.2022
Source of Sample	Supplied by the Client
Dimensions of Specimens in mm	150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0
Grade of Concrete	M25

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by the client and the results are tabulated here below

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Terrace Floor Column Concrete (Health Building in B Sector)	03.01 .2022	10.01.2022	7 Days	22500.00	8020	463.1	20.58
2		03.01 .2022	10.01.2022		22500.00	8215	452.7	20.12
3		03.01 .2022	10.01.2022		22500.00	8115	449.8	19.99

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

AE

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2582/2020					Date	01.02.2022
	TEST RESULTS ON CONCRETE CUBES						
Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.						
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.						
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.						
Name of Agency	Mr.H.V.Omkarappa Bengaluru.						
Clients Letter Dated	31.01.2022						
Date of Sample Received	31.01.2022						
Source of Sample	Supplied by the Client						
Dimensions of Specimens in mm	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
	150.0	x	150.0	x	150.0		
Grade of Concrete	M25						

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Terrace Floor Column Concrete (Health Building in B Sector)	03.01.2022	31.01.2022	28 Days	22500.00	8270	647.2	28.76
2		03.01.2022	31.01.2022		22500.00	8165	659.0	29.29
3		03.01.2022	31.01.2022		22500.00	8130	655.8	29.15

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

AE

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/S Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994Q1ZI PAN No: AACCK4994Q

Report No	KMTH/Cubes/2594/2021-22	Date	14.01.2022

TEST RESULTS ON CONCRETE CUBES

Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.
Name of Agency	Mr.H.V.Omkarappa Bengaluru.
Clients Letter Dated	13.01.2022
Date of Sample Received	13.01.2022
Source of Sample	Supplied by the Client
Dimensions of Specimens in mm	150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0
Grade of Concrete	M25

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by the client and the results are tabulated here below

Sl No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Terrace Floor Lift Machine Room Slab & Beam Concrete (Health Building in B Sector)	06.01.2022	13.01.2022	7 Days	22500.00	8025	440.6	19.58
2		06.01.2022	13.01.2022		22500.00	8090	435.2	19.34
3		06.01.2022	13.01.2022		22500.00	8045	453.2	20.14

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note; A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

AE

.....End of Report.....

Karnataka Material Test House Pvt Ltd. Bangalore

Approved by
Narayanswamy.B

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
Ph.:080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner

Karnataka Material Test House Pvt. Ltd.,

Soil Investigation, Concrete and NDT Testing ,Topo Survey, & Project management Consultancy

CIN No: U74210KA2004PTC035137 G S T No: 29AACCK4994G1ZI PAN No: AACCK4994G

KMTH/Cubes/2595/2020

TEST RESULTS ON CONCRETE CUBES

Date: 04.02.2022

Name of Client & Address	Bruhat Bengaluru Mahanagara Palike Yelahanka Project Division Bengaluru.
Name of Project & Address	onstruction of Health Building at B Sector in Ward No.04. In Yelahanka Satelite Town Sub Division.
Name of Consultant	M/s DSR Infratech, #1594, 3rd Main, Judicial Layout, New Airport raod GKVK Post, Bengaluru.
Name of Agency	Mr.H.V.Omkarappa Bengaluru.
Memo/Letter Dated	03.02.2022
Date of Sample Received	03.02.2022
Source of Sample	Supplied by the Client
Dimensions of Specimens in mm	150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0 150.0 x 150.0 x 150.0
Grade of Concrete	M25

Compressive Strength test as per guidelines of IS-516-1959 has been conducted on the concrete cube specimens supplied by

S.No	Cubes Pertaining to the concrete Cast at*(Details of structural Member Identification	Date of Casting*	Date of Testing	Age of Concrete on the date of test** (Days)	Contact Area (mm^2)	Weight of Specimen (gm)	Load In KN	Compressive Strength in Nmm^2
1	Terrace Floor Lift Machine Room Slab & Beam Concrete (Health Building in B Sector)	06.01.2022	03.02.2022	28 Days	22500.00	8165	652.0	28.98
2		06.01.2022	03.02.2022		22500.00	8090	648.6	28.83
3		06.01.2022	03.02.2022		22500.00	8105	658.7	29.28

1N/Sq.mm=10kg/Sq.cm(Approx) * As furnished by the client

Note: A Minimum of three cube specimens shall be supplied fo testing as per IS:516-1959

For Karnataka Material Test House Pvt Ltd.,

Prepared & Checked by
Nagaraj K S

.....End of Report.....

Karnataka Material Test House Pvt Ltd. ★ Bangalore ★

Approved by
Narayanswamy.B

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Note: 1)This reports is not to be reproduced except in full without our prior permission in writiing.
2)The results listed refer only to the tested samples nd applicable parameters.
3)Any correction in the report will be invalid.

Off & Lab :No. 8 (10/3), 4th cross, Basaveshwara layout, Nagashettihalli, RMV 2nd Stage, BENGALURU 560094
080- 2341 8668, 23511213 **Mobile: 94485 15258** E-mail: kmthblr@gmail.com www.karnatakamaterialtesthouse.com
M/s Karnataka Consultancy Services is Sister Concern of KMTHPL

Scanned by TapScanner